



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TEXAS 75202 - 2733

JUN 30 2015

Mrs. Shellie Chard-McClary *SCM*
Division Director
Water Quality Division
Oklahoma Department of Environmental Quality
707 North Robinson, P.O. Box 1677
Oklahoma City, Oklahoma 73101-1677

Re: Final Approval of Updates to the Oklahoma Water Quality Management Plan

Dear Mrs. Chard-McClary:

The U.S. Environmental Protection Agency (EPA), Region 6 has reviewed the updates to the State of Oklahoma Water Quality Management Plan (WQMP) transmitted to me on May 26, 2015. Following EPA's review and evaluation of the WQMP updates, EPA is pleased to approve the wasteload allocations (WLAs) for eleven facilities for May 2015 WQMP updates. These WLAs have been certified by the State of Oklahoma's Department of Environmental Quality and have undergone public participation as required by 40 CFR Part 25. A spread sheet is enclosed for details.

We appreciate the State of Oklahoma's continued efforts to maintain the WQMP in an efficient and timely manner. If you have any questions or concerns, please feel free to contact me directly at (214) 665-7101, or your staff may contact Syed A. Shahriyar at (214) 665-2783.

Sincerely,

William K. Honker, P.E.
Director
Water Quality Protection Division

Enclosure

cc: Derek Smithee, OWRD
Jennifer Wasinger, OWRB
Karen Miles, ODEQ

RECEIVED
JUL 06 2015
WATER QUALITY DIVISION

**Updates to the Oklahoma Water Quality Management Plan (208 Plan)
May 2015**

Nr.	Facility	NPDES #	Time Period	Design Flow	Waste Load Allocations (WLA) mg/L					Approval / Comment	EPA Technical Approval Date	EPA Final Action Date
					CBOD5 (mg/L)	BOD5 (mg/l)	TSS (mg/l)	NH3-N (mg/L)	DO (mg/L)			
1	Minco	OKG580057	Summer (Jun-Oct)	0.215	No Discharge					Approved	2/10/2015	6/30/2015
			Spring (Apr-May)		12	30	3.7	5				
			Winter (Nov-Mar)		30	90						
2	Tuttle	OK00Pending	Summer (Jun-Oct)	0.5	8	10	2.3	6.5		Approved	2/10/2015	6/30/2015
			Spring (Apr-May)			30						
			Winter (Nov-Mar)									
3	Mustang	OK0026816	Summer (Jun-Oct)	3	7	10	1.4	6.5		Approved	2/10/2015	6/30/2015
			Spring (Apr-May)		9	10	3.75	5				
			Winter (Nov-Mar)		13.5	22	4.1	5				
4	Oklahoma City-South Canadian	OK0038385	Summer (Jun-Oct)	8.66	3	10	0.6	6.5		Approved	2/10/2015	6/30/2015
			Spring (Apr-May)		5	10	0.8	7.4				
			Winter (Nov-Mar)		18	30	4.1	6				
5	OG&E McClain Generating Station	OK0045250	Summer (Jun-Oct)	0.189	9	10	3.2	4		Approved	2/10/2015	6/30/2015
			Spring (Apr-May)			30						
			Winter (Nov-Mar)									
6	Moore	OK0027391	Summer (Jun-Oct)	9	5	10	1.4	6.5		Approved	2/10/2015	6/30/2015
			Spring (Apr-May)		6	10	1.4	7.4				
			Winter (Nov-Mar)		15	20	4.1	7.4				

**Updates to the Oklahoma Water Quality Management Plan (208 Plan)
May 2015**

Nr.	Facility	NPDES #	Time Period	Design Flow	Waste Load Allocations (WLA) mg/L					Approval / Comment	EPA Technical Approval Date	EPA Final Action Date
					CBOD5 (mg/L)	BOD5 (mg/l)	TSS (mg/l)	NH3-N (mg/L)	DO (mg/L)			
7	NewCastle	OK0028614	Summer (Jun-Oct)	0.852							Approved	6/30/2015
			Spring (Apr-May)			20	30					
			Winter (Nov-Mar)									
8	Norman	OK0029190	Summer (Jun-Oct)	16	8		10	1.6	6.5		Approved	6/30/2015
			Spring (Apr-May)		13		30	4.1	5			
			Winter (Nov-Mar)			30	4.1	5				
9	Noble	OK0031755	Summer (Jun-Oct)	16			30		5		Approved	6/30/2015
			Spring (Apr-May)			30						
			Winter (Nov-Mar)				30					
10	Lexington	OK0022756	Summer (Jun-Oct)	0.261							Approved	6/30/2015
			Spring (Apr-May)			30	30					
			Winter (Nov-Mar)									
11	Purcell	OK0028533	Summer (Jun-Oct)	0.78							Approved	6/30/2015
			Spring (Apr-May)			30	90					
			Winter (Nov-Mar)									